

Operating instructions fixing light fixture

Attach the fixture with the screws/bolts and nuts and tighten them securely.

Tighten the screws of the adjustment bracket.

Feed the cable through the cable grommet.

Connect the fixture with a 2-core electrical cable (phase, neutral).

Tighten the pull connection and cable grommet securely so that the cable cannot come loose and the hermetic seal of the cable entry space is maintained.

Philips 400 Watt - 230Volt - 50Hz - IP65

The distance between the illuminated surface and the be less than 50cm.

The luminaire must never be mounted head. With other words, the cable entry compartment should always be located below the lighting compartment.

The fixture is only suitable for fixed mounting.

The luminaire must never be used without or with a damaged protective window.

Mounting / changing the lamp:

When mounting or changing the lamp, make sure that the switch is in the "off" position before opening the protective window.

For changing, use only lamps of the same type and read the installation instructions of the lamp.

Do not touch the glass of the lamp with bare hands. If you do, clean the glass with alcohol.

Close the window holder and make sure that the silicone sealing ring is correctly inserted into the designated recess. Place the sealing clips on the windshield holder and gently snap them in place to ensure a proper seal.

CAUTION:

After the lamp is turned off, never turn it back on immediately. Wait for about 5 minutes before turning the lamp on again.

Leave the lamp on for at least 5 minutes before turning it off.

Failure to observe this instruction will cause the lamp to fail.

HOIT lamps are checked at the factory and will not be reimbursed if defective.

